

**MOHAWK COUNCIL OF AKWESASNE
KAWEHNOKE DISTRICT**

**RFP FOR PROJECT 26-1005A
DIHE WATER AND WASTEWATER – RBC
REPLACEMENT AND UPGRADES PROJECT**

ADDENDUM NO. 3 TO RFP DOCUMENTS

Consisting of 1 Pages

This addendum is issued to respond to questions received.

1. *Please confirm who is responsible for PLC/HMI programming. Is it the Consultant or the General Contractor?*

MCA Response: Consultant to provide required design and contractor to complete programming during construction.

2. *Please confirm who is responsible for the configuration of all network equipment. Is it the Consultant or the General Contractor?*

MCA Response: General Contractor should be responsible for configuration of new network equipment.

3. *Please provide a copy of any SCADA standards, guidelines, and network/SCADA architecture drawings depicting the current state.*

MCA Response: MCA has panel drawings. We do not have SCADA standards and guidelines, any SCADA documentation will be provided to successful proponent.

4. *What manufacturers have been standardized for the HMI software and the PLC hardware?*

MCA Response: Allen Bradley is the manufacturer of the software and hardware.

5. *Is there any other SCADA software that requirements integration such as a Historian or remote alarm annunciation hardware/software?*

MCA Response: We have not been informed of any SCADA software requirements for integration, any integration issues/options will be reviewed with successful proponent.

I have read Addendum No. 3 and have included it in my Bid.

Consultant Signature

Date

-- END OF ADDENDUM NO. 3 --

Tuesday, June 2, 2026